

EASIO REMOTE


I/O MODULE I/O MODÜLÜ

GENERAL FEATURES

EASIO are devices that read / write the status of the digital output remotely and read the digital input remotely and keep the switching counts of digital inputs in memory. Digital output status can be read and changed via Modbus RTU. The last set digital output status is stored in the memory. It switches the output to the last set state after the power interruption, either when the device is energized or when the device is restarted.

PROPER USE AND SAFETY CONDITIONS

- Use a dry cloth to remove the dust from the device/clean the device. Avoid using alcohol, thinner or a corrosive material.
- Do not open the inside of the device. There are no parts that users can intervene inside.
- Device should be kept away from humid, wet, vibrant and dusty environments.

 The manufacturing company may not be kept responsible for unfavorable incidents that arise out of the failure to follow the above cautions.


	Digital Input	Digital Output	Relay Output	RS485	Order No
EASIO 1001	1	0	0	✓	260 001
EASIO 1100	0	0	1	✓	260 002
EASIO 1101	1	0	1	✓	260 003

GENEL ÖZELLİKLER

EASIO serisi cihazlar, sayısal çıkışı durumunu uzaktan okuyan/değiřtiren ve/veya sayısal giriřini uzaktan okuyan/sayısal giriřinin aktif olma sayısını hafızasında tutan cihazlardır. Sayısal çıkıř durumu, Modbus RTU üzerinden okunabilir ve deęiřtirilebilir. En son ayarlanan sayısal çıkıř durumu hafızada tutulur. Elektrik kesintisinden sonra cihazın enerjilenmesinde veya cihazın tekrar bařlama durumlarında çıkıřını son ayarlanan duruma getirir.


DOęRU KULLANIM VE GÜVENLİK ŐARTLARI

- Cihazı temizlemek-tozunu almak için kuru bir bez kullanınız Alkol, tiner veya ařındırıcı bir madde kullanmayınız.
- Cihazın ięini açmayınız. İçinde kullanıcıların müdahale edebileceęi parçalar yoktur.
- Cihaz rutubetli, ıslak, titreřimli ve tozlu ortamlardan uzak tutulmalıdır.


 Yukarıdaki önlemlerin uygulanmaması sonucu doęacak istenmeyen durumlardan üretici firma sorumlu deęildir.

	Dijital Giriř	Dijital Çıkıř	Röle Çıkıř	RS485	Sipariř No
EASIO 1001	1	0	0	✓	260 001
EASIO 1100	0	0	1	✓	260 002
EASIO 1101	1	0	1	✓	260 003


GENERAL VIEW & CONNECTIONS / GENEL GÖRÜNÜM ve BAęLANTILAR



EASIO 1101



EASIO 1001



EASIO 1100

LEDS AND KNOB

On the device; there is COMM indicating that the communication is ON, OUTPUT indicating that the digital output is active, and INPUT indicating that the digital input is active. The MODE knob is only read when the device is first turned on. There are 2 options of MODE knob. If the MODE knob is in the RUN position, the device continues to operate normally. If the device is power on when the MODE pot set to FACTORY SETTING, all the LEDs blink. If the MODE knob is not set to RUN position within 10 seconds, the device returns to the factory settings and starts again. If the MODE pot is set to RUN within 10 seconds, the device continues to operate normally.

IMPORTANT NOTE: If the device is energized when the mode knob is set to FACTORY SETTING, the MODE knob must be set to RUN after returning to the factory settings. If the MODE knob is left in FACTORY SETTING this will continue in infinite loop. In this case, since the EEPROM will be continuously recording data, the EEPROM will degrade over time and the device will not operate properly.

COMMUNICATION

The digital input status and the switching counts of digital inputs can be read via Modbus RTU. The switching count of digital inputs is stored in the non-deleted memory. Two parameters must be set for digital input. The first parameter is "Mode", the second parameter is "Delay Time". If the mode parameter is 0, the data read in the digital input is displayed without inversion. If the mode parameter is 1, the data read in the digital input is displayed with inversion. In order for digital input to be active, the input signal must be as active as the delay time. Device configurations can be changed via Modbus RTU. "Save" command should be sent to save the changed configuration. The digital output status is read with 01H-03H and written with functions 05H-0FH-06H-10H. The written values are processed as soon as they are sent, there is no need for the "Save" command. The digital input status is read with 02H-03H functions. The switching count of digital inputs read with the 03H function. If you want to change a value uint32_t with the function 06H (configuration data), the upper 16 bits of the uint32_t value must be sent first, and after that the lower 16 bits must be sent.

LEDLER VE POT

Cihaz üzerinde; cihaz enerjilenince yanan ON ledi, haberleşmenin olduęunu gösteren COMM ledi, sayısal çıkıřın aktif olduęunu gösteren OUTPUT ledi ve/veya sayısal giriřin aktif olduęunu gösteren INPUT ledi bulunmaktadır. MODE potu sadece cihaz ilk açıldıęı zaman okunmaktadır. MODE potunun 2 kademesi bulunmaktadır. MODE potu RUN konumunda ise cihaz normal çalışmasına devam eder. MODE potu FACTORY SETTING konumunda iken cihaz açılırsa, tüm LEDler blink yapmaya bařlar. Eęer 10 sn süresince MODE potu RUN konumuna geçirilmezse cihaz fabrika ayarlarına geri döner ve yeniden bařlar. Eęer 10sn den kısa bir süre içerisinde MODE potu RUN konumuna getirilirse cihaz normal çalışmasına devam eder.

ÖNEMLİ NOT: MODE potu FACTORY SETTING konumundayken cihaz enerjilendirilirse fabrika ayarlarına döndüldükten sonra MODE potu RUN konumuna getirilmelidir. Eęer MODE potu FACTORY SETTING konumunda bırakılırsa bu durum sonsuz döngü halinde devam eder. Bu durumda EEPROMa sürekli veri kaydı olacağı için EEPROM zaman içerisinde bozulur ve cihaz düzgün çalışmaz.

HABERLEŐME

Sayısal giriř durumu ve sayısal giriřin aktif olma sayısı Modbus RTU üzerinden okunabilir. Sayısal giriř aktif olma sayısı silinmeyen hafızada saklanır. Sayısal giriř için iki parametre ayarlanmalıdır. Birinci parametre "Mod", ikinci parametre "Gecikme Süresi" dir. Mod parametresi 0 ise sayısal giriře okunan veri terslenmeden gösterilir. Mod parametresi 1 ise sayısal giriř terslenerek gösterilir. Gecikme süresinde ise, ayarlanan süre (ms) boyunca dijital giriř aktif olmalıdır. Cihaz konfigürasyonları Modbus RTU üzerinden deęiřtirilebilir. Deęiřtirilen konfigürasyonun kayıt altına alınması için "Save" komutu gönderilmelidir. Sayısal çıkıř durumu 01H-03H fonksiyonları ile okunur, 05H-0FH-06H-10H fonksiyonları ile yazılır. Yazılan deęerler komut gönderilir gönderilmez işlenir, "Save" komutuna ihtiyaç yoktur. Sayısal giriř durumu 02H-03H fonksiyonları ile, Sayısal giriř aktif olma sayısı 03H fonksiyonu ile okunur. 06H fonksiyonu ile uint32_t bir deęer deęiřtirilmek istenirse(konfigürasyon verileri), ilk önce uint32_t deęerin üst 16 biti, daha sonra alt 16 biti gönderilmelidir.

Address	Variable	Type	Read / Write	Function	Selection / Description
40001	Digital/Relay Output	uint16_t	R/W	03H-06H-10H	SEL1
40002	Digital Input	uint16_t	RO	03H-06H-10H	SEL2
40003	Digital Input switching count	uint32_t	RO	03H-06H-10H	
40011	Baud rate	uint16_t	R/W	03H-06H-10H	SEL3
40012	Slave Id	uint16_t	R/W	03H-06H-10H	Min = 1 Max = 247
40013	Input Mode	uint16_t	R/W	03H-06H-10H	SEL4
40014	Input Delay Time	uint32_t	R/W	03H-06H-10H	Min = 10 msec Max = 65535 msec
40016	Order Number	uint32_t	RO	03H	
40018	Serial Number	uint32_t	RO	03H	
40100	Save Command	uint32_t	WO	10H	Value:16909060
40200	Clear DI Switching Count	uint32_t	WO	10H	Value:16909060

Modbus Address Table

	SEL 1	SEL 2	SEL 3	SEL 4
0	off	off	1200	Active High
1	on	on	2400	Active Low
2			4800	
3			9600	
4			19200	
5			38400	
6			57600	
7			115200	

Selection Table

Adres	Parametre	Veri Tipi	Read /Write	Fonksiyon	Seçim/ Açıklama
40001	Dijital/Röle Çıkış	uint16_t	R/W	03H-06H-10H	SEL1
40002	Dijital Giriş	uint16_t	RO	03H-06H-10H	SEL2
40003	Dijital giriş anahtarlama sayısı	uint32_t	RO	03H-06H-10H	
40011	Baud rate	uint16_t	R/W	03H-06H-10H	SEL3
40012	Köle ID	uint16_t	R/W	03H-06H-10H	Min = 1 Max = 247
40013	Giriş Tipi	uint16_t	R/W	03H-06H-10H	SEL4
40014	Giriş gecikme süresi	uint32_t	R/W	03H-06H-10H	Min = 10 msec Max = 65535 msec
40016	Sipariş Numarası	uint32_t	RO	03H	
40018	Seri Numarası	uint32_t	RO	03H	
40100	Kayıt Adresi	uint32_t	WO	10H	Değer:16909060
40200	Dijital giriş sayısını silme	uint32_t	WO	10H	Değer:16909060

Modbus Adres Tablosu

	SEL 1	SEL 2	SEL 3	SEL 4
0	off	off	1200	Yükselen Kenar
1	on	on	2400	Düşen Kenar
2			4800	
3			9600	
4			19200	
5			38400	
6			57600	
7			115200	

Seçim Tablosu

TECHNICAL SPECIFICATIONS / TEKNİK ÖZELLİKLER

SUPPLY

Voltage85..265V AC/DC
Frequency45..65 Hz

DIGITAL INPUTS

Voltage24..265V AC/DC

RELAY OUTPUTS

Max. switchig current.....: 10 A
Max. switchig voltage.....: 250 VAC
Max. switchig power.: 1250VA

COMMUNICATION

Isolated RS485 Port.....: 1 Channel, ESD and over current/voltage protected, programmable, 1200 bps to 115200 bps baud rate.

OPERATING TEMPERATURE/ STORAGE TEMPERATURE / RELATIVE HUMIDITY

-20°C..+60°C / -30°C..+80°C / maximum 95% No Condensation

PROTECTION CLASS

IP20

BESLEME

Gerilim 85..265V AC/DC
Frekans45..65 Hz

DİJİTAL GİRİŞLER

Gerilim 24..265V AC/DC

RÖLE ÇIKIŞLARI

Maks anahtarlama akımı.....: 10 A
Maks. anahtarlama gerilimi.....: 250 VAC
Maks. anahtarlama gücü.....: 1250VA

İLETİŞİM

İzoleli RS485 Port:1 Kanal, ESD ve aşırı akım/gerilim korumalı programlanabilir, 1200bps – 115200 bps iletişim hızı.

ÇALIŞMA SICAKLIĞI / DEPOLAMA SICAKLIĞI / BAĞIL NEM

-20°C..+60°C / -30°C..+80°C / Maksimum 95%, yoğunlaşma yok

KORUMA SINIFI

IP20