



Certificate of Compliance

Certificate: 70077624

Master Contract: 254620

Project: 70077624

Date Issued: 2017-12-04

Issued to: **Klemsan Elektrik Elektronik Inc**
Kızılızüüm Mahallesi,
Kemalpaşa Kızılızüüm Caddesi No: 15
Kemalpaşa, İzmir 35730
TURKEY
Attention: Emre Atalay

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Mike W. Gryschuk*
Mike W. Gryschuk, C.E.T.

PRODUCTS

CLASS 6228 01 - WIRE CONNECTING DEVICES – Terminal Assemblies

Rail mount terminal blocks for solid and stranded copper conductors, Groups B,D:

Cat No ASK 5LD 24 V AC/DC, rated 10A, 24V, for Nos 10-26 AWG, 1Nm torque.
Cat No ASK 5LD 110 V AC/DC, rated 10A, 110V, for Nos 10-26 AWG, 1Nm torque.
Cat No ASK 5LD 220 V AC/DC, rated 10A, 220V, for Nos 10-26 AWG, 1Nm torque.
Cat No ASK 5S, rated 10A, 300V, for Nos 10-26 AWG, 1Nm torque.
Cat No PYK 6, spring force, rated 35A, 600V, for Nos 8-20 AWG.
Cat No PYK 6T, spring force, grounding, rated 600V, for Nos 8-20 AWG.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 0.4-04, 3rd Ed - Bonding of Electrical Equipment (Cat No PYK 6T only)
CSA Std. C22.2 No. 158-10, 3rd Ed - Terminal Blocks



Supplement to Certificate of Compliance

Certificate: 70077624

Master Contract: 254620

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70077624	2017-12-04	Original Certification Cat Nos ASK 5LD 24V, ASK 5LD 110V, ASK 5LD 220V, ASK 5S, PYK 6, PYK 6T.