

# Certificate of Compliance

Certificate: 2481403

Master Contract: 254620

Project: 2481403

Date Issued: February 24, 2012

Issued to: Klemsan Elektrik Elektronik San.ve Tic.A.S.  
Kemalpassa Yolu 3.km  
35170 Izmir  
TURKEY

*The products listed below are eligible to bear the CSA Mark shown*



Issued by: G. Foulem  
*G. Foulem*

## PRODUCTS

CLASS 6228 01 – WIRE CONNECTING DEVICES – Terminal Assemblies

**Certificate:** 2481403



**CSA INTERNATIONAL**

**Master Contract:** 254620

**Project:** 2481403

**Date Issued:** February 24, 2012

Terminal Blocks for rail mounting with cage clamp terminals for use with stranded and solid insulated conductors:

Cat. No.	Voltage [V]	Group	Wire-Range [AWG]	Current [A]	Torque [Nm]	Remarks
AVK 2,5	600	B,C	28-12	20	0.5	
AVK 4	300	B,C	28-10	30	0.8	
AVK 4	600	D	28-10	30	0.8	
AVK 4T	-	-	28-10	-	0.8	PCTB
AVK 6	300	B,C	28-8	40	1.2	
AVK 6	600	D	28-8	40	1.2	
AVK 10	300	B,C	16-6	65	1.4	
AVK 10	600	D	16-6	65	1.4	
AVK 10T	-	-	16-8	-	1.4	PCTB
AVK 16 RD	600	B,C	12-4	80	1.2	
AVK 16T RD	-	-	12-4	-	1.2	PCTB
AVK 35 RD	600	B,C	12-2	115	2.5	
AVK 35T RD	-	-	12-2	-	2.5	PCTB

Notes:

1. Certified as a component for use only where the suitability of the final combination is determined by CSA International or other NRTL.
2. Suffixes may be added to the Catalogue numbers, to denote colour and other mechanical variations not affecting the electrical properties.

### **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 0 - General Requirements Canadian Electrical Code, Part II  
CSA Standard C22.2 No. 158 - Terminal Blocks

### **MARKINGS**

- (a) The following marking details are moulded or ink-stamped in a permanent manner on each terminal block:
- Submitter's identification: name, trademark or other descriptive marking by which the organization responsible for the product can be identified (e.g. Master Contract number 254620 adjacent to the CSA mark);
  - The CSA monogram.
- (b) The following marking details shall be marked on each device, or, when this is not practicable, on the smallest packaging size:
- Catalogue model or type designation;
  - Maximum voltage;
  - Conductor range;
  - Ampere rating;
  - Torque values.



CSA INTERNATIONAL

## *Supplement to Certificate of Compliance*

**Certificate:** 2481403

**Master Contract:** 254620

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
2481403	February 24, 2012	Original Certification of terminal block Series AVK.